


SUMMARY OF FINDINGS AND CONCLUSIONS


There are 6 facilities with ASTs within one (1) mile of the activity site. The separation distance was calculated for each facility. There is 2000 gallon AST located at the Edens Construction Company facility. Pursuant to the HUD ASD calculator, the acceptable separation distance (ASD) for people is 131.27 feet and 22.15 feet for buildings. The activity site is located ~1,364 feet from ASTs which is an acceptable separation distance. See discussion above regarding the FDEP Map Direct website and Waste Management Maps access process to create the AIR STCM map for the 1-mile radius review of facilities.

The activity is in compliance with HUD's environmental requirements as it relates only to the provision of replacement/construction of a residential structure under the HOME S/F Owner Occupied Housing Replacement Countywide Program. Funds may be committed and drawn-down for this activity.


Preparer Signature

Melanie Borkowski, Regulatory Specialist
Name and Title

June 24, 2019
Date


Responsible Entity Official Signature

Jonathan Brown, Director, HES
Title

6/25/19
Date

G:\ENVIRON ERRS\ERRS\Projects\2018-2019\HOME\HOME SF Owner Occupied Housing Replacement Prog Checklists sites\South Bay\275 NW 12th Ave\Site Strategy Checklist 15-20.doc