4/12/2024 4:25:00 PM

10136681

## Palm Beach County Fleet Management Asset Maintenance History 2001 MOTOROLA C & E INC. EMERGENCY Generator @ Boynton

Total Hours: 0.00 Labor: 0.00 Parts: 0.00 Comm: 0.00 Charged: 0.00

Work Order: 238751 Meter: 10 In Date: 04/18/2002 Closed: 04/18/2002

Problem: FUEL SWAP

Work Completed - Fuel Swap For Hurricane Season - Boynton And Back 2xs			Parts Issued Shop Supplies Kathon Preservitive Diesel Fuel 1.5 Micrbcide		<b>Quantity</b> 1.00 0.50						
						- Shop Supplies			Bg Conditioner Diesel (2271) Use 2401		7.00
									Kathon Preservitive Diesel Fuel 1.5 Micrbcide		-0.50
Bg Conditioner Diesel (2271) Use 2401		-7.00									
Н	ours: 0.00	Comm: 0.00	Labor: 0.00	Parts: 0.00	Total: 0.00						

Total Hours: 0.00 Total Labor: 0.00 Total Comm: 0.00 Total Parts: 0.00