

10/6/2017
10:13:06AM

Palm Beach County Fleet Management Asset Maintenance History

Asset: 10124230 1997 GENERAC 97A075495 80-KW EMERGENCY GENERATOR

Workorder: 34617

Problem: P.M.PARTS

Meter Reading: 0		Labor		Parts	
In Date: 02/11/2000	Close Date: 03/21/2000	Hours	Description		Quantity
-	Battery Replace Battery Clean Terminal Battery	9.50	F4DLT BATTERY		1.00
-	Annual Pm Service		96701 OIL FILTER		1.00
-	Set Up And Waste Removal		90749 AIR FILTER		1.00
-	Road Time		15/40 OIL		16.00
-	Shop Supplies		C1191A FUEL FILTER LBF L296F WIX 33166		2.00
			SHOP SUPPLIES		1.00
Parts Charge: 383.90		Labor Charge: 427.50			

Workorder: 43267

Problem: EMERGENCY GENERATOR TEST

Meter Reading: 74		Labor		Parts	
In Date: 07/27/2000	Close Date: 08/02/2000	Hours	Description		Quantity
-	Quarterly Pm Service	2.00	SHOP SUPPLIES		1.00
-	Shop Supplies				
Parts Charge: 2.00		Labor Charge: 90.00			

Workorder: 47064

Problem: PM SERVICE

Meter Reading: 83		Labor		Parts	
In Date: 10/10/2000	Close Date: 10/13/2000	Hours	Description		Quantity
-	Pm	2.00	15/40 OIL		2.00
-	Shop Supplies		SHOP SUPPLIES		1.00
Parts Charge: 4.34		Labor Charge: 90.00			

Workorder: 47368

Problem: EMERGENCY GENERATOR TEST

Meter Reading: 83		Labor		Parts	
In Date: 10/17/2000	Close Date: 10/20/2000	Hours	Description		Quantity
-	Pm Service	2.00	SHOP SUPPLIES		1.00
-	Shop Supplies		15/40 OIL		2.00
Parts Charge: 4.34		Labor Charge: 90.00			

10/6/2017
10:13:06AM

Palm Beach County Fleet Management Asset Maintenance History

Asset: 10124230 1997 GENERAC 97A075495 80-KW EMERGENCY GENERATOR

Workorder: 133641

Problem: ANNUAL P.M.

Meter Reading: 0		Labor		Parts	
In Date: 01/31/2001	Close Date: 03/30/2001	Hours	Description	Quantity	
- Annual Pm Service		9.50	C1191A FUEL FILTER LBF L296F WIX 33166	1.00	
- Set Up And Waste Removal			C1191A FUEL FILTER LBF L296F WIX 33166	1.00	
- Road Time			15/40 OIL	16.00	
- Shop Supplies			OIL FILTER 96701	1.00	
			SHOP SUPPLIES	1.00	
Parts Charge: 51.08		Labor Charge: 427.50			

Workorder: 141841

Problem: TREAT DIESEL FUEL

Meter Reading: 83		Labor		Parts	
In Date: 06/21/2001	Close Date: 07/10/2001	Hours	Description	Quantity	
- Biocide Fuel Treatment		1.40	SHOP SUPPLIES	1.00	
- Stabilizer Fuel Treatment			KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	1.00	
- Shop Supplies			BG CONDITIONER DIESEL (2271) USE 2401	1.00	
Parts Charge: 23.20		Labor Charge: 63.00			

Workorder: 236244

Problem: FUEL SWAP

Meter Reading: 112		Labor		Parts	
In Date: 03/12/2002	Close Date: 03/15/2002	Hours	Description	Quantity	
- Fuel Swap For Hurricane Season; Fuel Was Treated		2.50	KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	1.00	
- Fleet To Palm Tran-Electronics Way And Back			SHOP SUPPLIES	1.00	
- Shop Supplies					
Parts Charge: 13.43		Labor Charge: 125.00			

Workorder: 336259

Problem: FUEL SWAP FOR HURRICANE SEASON

Meter Reading: 115		Labor		Parts	
In Date: 03/12/2003	Close Date: 03/13/2003	Hours	Description	Quantity	
- Fuel Swap Hurricane Season		2.50	KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	2.00	
- Palm Tran And Back.			BG CONDITIONER DIESEL (2271) USE 2401	2.00	
- Shop Supplies			SHOP SUPPLIES	1.00	
Parts Charge: 29.24		Labor Charge: 125.00			

10/6/2017
10:13:06AM

Palm Beach County Fleet Management Asset Maintenance History

Asset: 10124230 1997 GENERAC 97A075495 80-KW EMERGENCY GENERATOR

Workorder: 441345

Problem: FUEL SWAP FOR HURRICANE SEASON

Meter Reading: 159	Labor	Parts	
In Date: 04/14/2004	Hours	Description	Quantity
- Po-Fuel Swap For Hurricane Season	1.00	KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	2.00
- Palm Tran And Back.		BG CONDITIONER DIESEL (2271) USE 2401	2.00
- Shop Supplies		SHOP SUPPLIES	1.00
Parts Charge:	26.74	Labor Charge:	50.00

Workorder: 457472

Problem: BATTERY

Meter Reading: 188	Labor	Parts	
In Date: 09/24/2004	Hours	Description	Quantity
- Parts Only		GROUP 4DLT BATTERY (ACD 721A)	1.00
Parts Charge:	101.69	Labor Charge:	0.00

Workorder: 540088

Problem: FUEL SWAP FOR HURRICANE SEASON

Meter Reading: 341	Labor	Parts	
In Date: 03/25/2005	Hours	Description	Quantity
- Fuel Swap	2.50	BG CONDITIONER DIESEL (2271) USE 2401	2.00
- Gen And Back		SHOP SUPPLIES	1.00
- Shop Supplies		KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	2.00
Parts Charge:	30.65	Labor Charge:	125.00

Workorder: 638088

Problem: HURRICANE FUEL SWAP

Meter Reading: 359	Labor	Parts	
In Date: 04/27/2006	Hours	Description	Quantity
- Fuel Swap	4.00	BG CONDITIONER DIESEL (2271) USE 2401	2.00
- Fm-Palm Tran North		KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	2.00
- Shop Supplies		SHOP SUPPLIES	1.00
Parts Charge:	37.70	Labor Charge:	50.00

10/6/2017
10:13:06AM

Palm Beach County Fleet Management Asset Maintenance History

Asset: 10124230 1997 GENERAC 97A075495 80-KW EMERGENCY GENERATOR

Workorder: 733584

Problem: HURRICANE FUEL SWAP

Meter Reading: 359	Labor	Parts	Quantity
In Date: 01/31/2007	Hours	Description	
- Fuel Swap	4.00	SHOP SUPPLIES	1.00
- Palm Tran North			
- Shop Supplies			
Parts Charge:	2.00	Labor Charge:	110.00

Workorder: 935297

Problem: FUEL SWAP FOR HURRICANE SEASON

Meter Reading: 359	Labor	Parts	Quantity
In Date: 03/18/2009	Hours	Description	
- Fuel Swap For Hurricane Season	6.00	KATHON PRESERVITIVE DIESEL FUEL 1.5 MICRBCIDE	12.00
- Gen & Back 2 Trucks,2 Drivers.		SHOP SUPPLIES	1.00
- Shop Supplies		BG CONDITIONER DIESEL (2271) USE 2401	1.00
Parts Charge:	44.90	Labor Charge:	180.00

Total Parts Charges: **755.21** Total Labor Charges: **1,953.00** Total Comm. Charges: **0.00**