



Minimòm Estanda pou Bouch Dlo Kont Ensandi



- Bouch dlo kont ensandi dwe konfòme ak edisyon aktyèl pou:
- Kòd Prevansyon Florid Kont Ensandi "FFPC"
- Amanman Lokal Kòd Prevansyon Kont Ensandi nan Florid
- NFPA 14, Estanda pou Enstalasyon Sistèm Ponp Vètikal ak Tiyo
- NFPA 24, Estanda pou Enstalasyon Koneksyon Sèvis Prive ak Depandans yo
- NFPA 25, Estanda pou Enspeksyon, Tès, ak Antretyen Sistèm Pwoteksyon Dife ki a Baz Dlo
-
- Tout nouvo enstalasyon koneksyon pou depatman ponpye dwe lokalize pa plis ke san pye (100') de bouch dlo kont ensandi a e mezire selon aksè machin ponpye a. Aksè machin depatman ponpye a dwe detèmine pa AHJ a (Otoriti ki gen Jiridiksyon).
-
- Abitasyon detache youn ak de fanmi. Bouch Dlo Kont Ensandi dwe a omwens katsan pye (400') de kote ki pi elwanye de bilding la, mezire pou aksè machin ak sou kote bilding nan. Distan maksimòm ant bouch dlo kont ensandi a pa dwe depase 500 pye.
-
- Lè li ekzije pa AHJ a, bouch dlo kont ensandi ki gen domaj swit a aksidan machin dwe pwoteje sof si li lokalze tou prè yon vwa piblik.
-
- Lè rezèv dlo oswa bouch dlo kont ensandi yo pa fonksyone akòz de entreyen oswa reparasyon, yon endikatè ki vizib ki apwouve pa AHJ a dwe itilize pou endike ke bouch dlo a pa fonksyone.
-
- Yon minimòm 60 pous de espas vid dwe obsève nan alantou tout bouch dlo kont ensandi yo.



18" Minimòm



36" Maksimòm

Mitan priz tiyo a pa dwe mwens ke 18 pous
oswa pi wo ke 36 pous anlè nivo final la.

