

General Safety
Operations/Setup/Training Manual
Wheel Chocks
Carbon Monoxide Detector (UL Listed) installed in truck – test device monthly
Propane Gas Detector (UL Listed) - test device monthly
Water Spray Bottle (10% Soap solution for leak checks)
Propane leak log
Cooking Safety
UL300 Hood Suppression System (Report & correct deficiencies)
Cleaning of Hood and exhaust system for grease buildup (current sticker)
Cleaning of grease buildup interior of truck (Ex: Nozzle caps, griddle, deep-fat fryer, charbroilers, exhaust)
Manual Suppression Activation pull located by exit doorway or AHJ approval
Fryer Separation if required (8" baffle or 16" separation, Not Installed or separated)
Fire Extinguishers
Minimum 2A:20BC (Red), Unobstructed & Inspected
Minimum 6L Class K (Silver) Unobstructed & Inspected
A warning placard near K extinguisher-states activate hood first
LP Gas Safety
Signage, "No Smoking" (minimum 2 Inch lettering/numbers)
Signage Propane Container Marking (minimum 2 Inch lettering/numbers)
Signage – "Emergency Gas Shut-Off Valve" (minimum 2 Inch lettering/numbers)
Exterior LP Emergency Shut Off Valve - 1/4 Turn, Accessible
LP 3rd party Inspection Receipt for piping & connection
LP Tanks – No signs of Damage (Denting, Bulging or Corrosion)
Maximum 200 lbs. (no more than 4 Tanks)
Current Hydrostatic Testing Markings (Manufacture Date and Retest Dates if applicable)
LP Tanks Securely mounted
LP Gas Hose Cabinet - properly protected flexible connector/fastening/rubber grommet
LP Gas Hose Marking – Stamped approved for LP Gas (Wrought iron, Steel, Brass, Copper, Polyethylene, Austenitic)
Electrical Safety
Extension Cords - Proper Type & Use
Generator / Extension Cords - Good Condition
Electrical Disconnect shall be legibly Marked
Electrical Panel/Outlets - Good Condition, Clean, No Missing Covers
(EVENT Specific Inspection Items) This is in addition to what is required above
Parking - 10 foot Clearance ALL Directions (No Obstructing Fire Lanes/Fire Hydrants)
Portable Generators - shall not be fueled while the engine is running nor when the generator is hot
Generator Placement / Exhaust - Isolated from public (guarding device such as fence enclosure)
Generator Fuel Storage – Away from Heat Source (not in truck interior)