







EXHIBIT A

ARTICLE 15 – HEALTH REGULATIONS  
SUMMARY OF AMENDMENTS  
(Updated 03/27/2014)

1  
2 Part 1. ULDC Art. 15.B.13, Operation and Maintenance [Related to Drinking Water Supply  
3 Systems] (page 16 of 24), is hereby amended as follows:  
4

Reason for amendments: [Health Department] To place fire hydrant testing responsibility on the operators of systems and the Fire Department.

5 CHAPTER B (PBC ENVIRONMENTAL CONTROL RULE II) DRINKING WATER SUPPLY SYSTEMS

6 Section 13 Operation and Maintenance

- 7  
8 ....  
9 I. Fire hydrant maintenance and fire flow testing shall be the responsibility of the owner of the fire  
10 hydrant. Maintenance and fire flow testing shall be performed in accordance with the "Standards  
11 of the American Water Works Association Manual M-17" and as indicated below: [Ord. 2006-004]  
12 1. A routine maintenance program shall be established for each fire hydrant. [Ord. 2006-004]  
13 2. Fire flow testing of hydrants shall be performed on a three year cycle, such that all hydrants  
14 in a system are fire flow tested at least once every three years unless recommended by the  
15 manufacturer or the Department to be more frequent. Owners of fire hydrants which do not  
16 utilize local fire departments or water utility departments to perform or oversee the fire flow  
17 testing shall ~~report all available results of testing to the local fire department and water utility~~  
18 ~~department have completed all testing and submitted a letter of completion to the local fire~~  
19 ~~authority~~ by January 1st of each year with all hydrants accounted for within the required  
20 cycle. These records shall be maintained on site for review by the applicable fire authority.  
21 [Ord. 2006-004] [Ord. 2013-002]  
22 3. The minimum required fire flow from fire hydrants shall be determined as per Art.  
23 15.B.8.A.21.a. [Ord. 2006-004]  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61

U:\Zoning\CODEREV\2014\BCC Hearings\Round 2014-01\2 First Reading\Health Ordinance\Exh. A - Art. 15, Health Regulations.docx

Notes:  
Underlined indicates **new** text.  
~~Stricken~~ indicates text to be **deleted**. ~~Stricken and italicized~~ means text to be totally or partially relocated. If being relocated destination is noted in bolded brackets **[Relocated to: ]**.  
*Italicized* indicates text to be relocated. Source is noted in bolded brackets **[Relocated from: ]**.  
.... A series of four bolded ellipses indicates language omitted to save space.