

**ADDENDUM NO. 1**

**PALM BEACH COUNTY WATER UTILITIES DEPARTMENT  
PALM BEACH COUNTY, FLORIDA  
Continuing Contract for Wastewater Gravity Lines & Manhole Rehabilitation  
Project No. WUD 16-094R**

**Bid Documents will be received by the PALM BEACH COUNTY WATER UTILITIES DEPARTMENT, Palm Beach County, Florida until 2:00 P.M. on Wednesday, August 9, 2017.**

**TO ALL BIDDERS AND OTHERS CONCERNED:**

Contractors submitting proposals for the above referenced project shall take note of the clarification to the Contract documents that shall become a part of the contract.

**Bidders are reminded to acknowledge Addendum No. 1 on Bid Form-3**

Dated this 1<sup>st</sup> day of August 2017

Palm Beach County  
Water Utilities Department

*Pollop Phonpornwithoon*

Pollop Phonpornwithoon, E.I. PMP  
Project Coordinator

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM NO. 1 (PAGES AD1-1 – AD1-2) BY SIGNING BELOW – EMAIL PPhonpornwithoon@pbewater.com FAX (561) 493-6113 IMMEDIATELY.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Company

**Questions submitted by Contractors have been answered below:**

Question: 1. On page 3, 5, 55 and 56 of the bid documents it says fold-and-form lining method is a form of service allowed for rehabilitation of wastewater gravity pipes on this project. There are no specifications included in the technical specs for the fold and form (Section 02958 in previous bids). Can the specifications be sent for fold-and-form pipe for this contract please?

Answer: 1. Cure in Place Pipe (CIPP) lining method will be the method used by this Contract.

Question: 2. Would the County consider changing bid items 1-24 to unit of measure of EACH or state a minimum footage per point repair? Without a minimum, the bidders will need to price the repairs assuming a possible 4' one stick repair. The June bid that the county put out had similar scope with these items as EACH instead of LF.

Answer: 2. The "June bid" (WUD 15-024) was based on determined scope. For this Contract, the scope of each point repair will depend on each Work Authorization. The Point Repair line item will be used for emergency pipe repair encounter during lining operation.