

## **Section 3 –Wastewater Design Standards and Details Summary of Revisions**

### **September 2024 Updates**

Based on Palm Beach County Water Utilities Department (WUD) evaluation of the Wastewater Design Standards and Details issued in March of 2023 as part of the Palm Beach County Water Utilities Department Minimum Design and Construction Standards revised to update various lift station details only.

### **WASTEWATER DESIGN STANDARDS:**

No current revisions to the written design standards portion.

### **WASTEWATER DESIGN INDIVIDUAL STANDARD DETAILS:**

All individual standard details are dated to reflect either “6/2019” revision, “01/2023” revision or current revision “8/2024”. The individual details dated August 2024 revised for lift station improvements were notated with an asterisk (\*).

1. 47S: Revised control panel dimension to fence and added enlarged detail for future skid mounted generator.
2. 48S: Added notes M and N for future skid mounted generator.
3. 49SA: Added drop bowl in place of drop pipe tee.
4. 49SB: General revision to replace drop pipe tee with drop bowl and notes.
5. 49SC: General revision to valve vault pressure transmitter detail and notes.