

Approved Materials and Equipment List Summary of Revisions

October, 2021 Updates

Based on the Product Evaluation Committee findings, the following manufacturers/products have been revised, removed and/or added to the Palm Beach County Water Utilities Department Approved Materials and Equipment List:

POTABLE WATER SYSTEM:

1. PW 2: Revised applicable pipe size on A(4) & A(6) and updated manufacturer allowable deflection in degrees. Added Atkore to Heritage Plastics on C(1) due to Atkore now owns them.
2. PW 4: Removed A(3) due to that manufacturer does not deliver to the United States – Canada only.
3. PW 9: Revised product (1) to reflect current manufacturer product number.
4. PW 40: Revised product (1) to reflect current manufacturer product number and add (2) Alternative.
5. PW 62: Updated component heading; Created separate sub-category for each type of insertion valve.
6. PW 64: Revised manufacturer product number on B(1).
7. PW 81: Revised manufacturer product series on (1) & (2).
8. PW84: Remove due to Standards no longer require boots at the end of casings.

WASTEWATER SYSTEM:

1. WW 2: Revised applicable pipe size on A(4) & A(6) and updated manufacturer allowable deflection in degrees. Added Atkore to Heritage Plastics on C(1) due to Atkore now owns them.
2. WW 4: Removed A(3) due to that manufacturer does not deliver to the United States – Canada only.
3. WW 7: Add manufacturer name - (7) due to it meets WW 7 requirements.
4. WW 12: Revised product (5) to reflect current manufacturer product number.
5. WW 41: Updated component heading; Revised product (2) to reflect current manufacturer product number.
6. WW 64: Updated component heading; Created separate sub-category for each type of insertion valve.
7. WW 76: Remove due to Standards no longer require boots at the end of casings.
8. WW 77: Revised manufacturer product name on (1); Added (2) to reflect current manufacturer/product name on lift station Bill of Materials Standard Detail.

RECLAIMED WATER SYSTEM:

1. RW 2: Revised applicable pipe size on A(4) & A(6) and updated manufacturer allowable deflection in degrees. Added Atkore to Heritage Plastics on C(1) due to Atkore now owns them.
2. RW 4: Removed A(3) due to that manufacturer does not deliver to the United States – Canada only.
3. RW 9: Revised product (5) to reflect current manufacturer product number.
4. RW 54: Updated component heading; Created separate sub-category for each type of insertion valve.
5. RW 65: Remove due to Standards no longer require boots at the end of casings.

LINE MAINTENANCE REPAIR MATERIALS:

1. MR 20: Revised manufacturer name on (4).
2. MR 21: Revised manufacturer name on (4).
3. MR 25: Revised manufacturer name on (4).
4. MR 26: Revised manufacturer name on (4).
5. MR 27: Revised manufacturer name on (4).
6. MR 29: Revised manufacturer name on (1), (2) & (3).
7. MR 30: Revised manufacturer name on (2).
8. MR 34: Revised manufacturer name on (3).
9. MR 35: Revised manufacturer name on (3).
10. MR 37: Revised manufacturer name on (3).
11. MR 44: Revised manufacturer name on (2).
12. MR 51: Revised manufacturer name on (2).
13. MR 52: Revised manufacturer name on (2).
14. MR 83: Product was removed in last issuance so labeled it to read “left blank intentionally” as not to renumber the MR section.
15. MR 92: Revised manufacturer product series on (1) & (2).
16. MR 93: Updated component heading; Created separate sub-category for each type of insertion valve.
17. MR 94: Remove - ultrasonic transducer is no longer used.
18. MR 101: Removed ASTM reference and added (2) SCS+L by BLD Services as a second approved lateral lining
19. MR 134: Revised manufacturer product name on (1); Added (2) to reflect current manufacturer/product name on lift station Bill of Materials Standard Detail.

WATER TREATMENT PLANT EQUIPMENT:

No changes/updates required for October 2021 issuance.

WASTEWATER TREATMENT PLANT EQUIPMENT:

No changes/updates required for October 2021 issuance.