



Egzijans Tès Debi pou Bouch Dlo Kont Ensandi



Daprè edisyon aktyèl pou Amanman Lokal Palm Beach County pou Kòd Prevansyon kont Ensandi nan Florid, pri ki asosye avèk tès debi bouch dlo kont ensandi e efekte pa Palm Beach County Fire-Rescue se twasan dola (\$300) pa tès debi.

Pou demann yon tès debi pou bouch dlo kont ensandi, tanpri bay enfòmasyon sila yo:

“Lèt Transmisyon”, ki enkli:

Tit Transmisyon ki dwe ekri “Request for Fire Hydrant Flow Tès” (Demann pou tès Debi Bouch Dlo kont Ensandi)

Mande pa, Kontak:

Nimero Kontak:

Email Kontak:

Non Pwojè a:

Adrès Pwojè a:

Tip Pwojè a: “Nouvo” oswa “Egzistan”

Kantite Bouch Dlo kont Ensandi ki dwe Teste

Plan Sit Pwojè a



2. Yon chèk oswa yon manda postal peyab a “BCCPBC” oswa “Board of County Commissioners, Palm Beach County”

3. Lèt Transmisyon, Plan sit Pwojè a ak chèk oswa manda postal dwe delivre oswa poste a:

Palm Beach County Fire Rescue
Reference: Fire Hydrant Flow Test
2300 N Jog Rd, Suite IE-40
West Palm Beach, FL 33411

Pou plis enfòmasyon sou Sekirite kont Ensandi peza la a





Minimòm Estanda pou Bouch Dlo Kont Ensandi



- Bouch dlo kont ensandi dwe konfòme ak edisyon aktyèl pou:
- Kòd Prevansyon Florid Kont Ensandi "FFPC"
- Amannman Lokal Kòd Prevansyon Kont Ensandi nan Florid
- NFPA 14, Estanda pou Enstalasyon Sistèm Ponp Vètikal ak Tiyo
- NFPA 24, Estanda pou Enstalasyon Koneksyon Sèvis Prive ak Depandans yo
- NFPA 25, Estanda pou Enspeksyon, Tès, ak Antretyen Sistèm Pwoteksyon Dife ki a Baz Dlo
-
- Tout nouvo enstalasyon koneksyon pou depatman ponpye dwe lokalize pa plis ke san pye (100') de bouch dlo kont ensandi a e mezire selon aksè machin ponpye a. Aksè machin depatman ponpye a dwe detèmine pa AHJ a (Otoriti ki gen Jiridiksyon).
-
- Abitasyon detache youn ak de fanmi. Bouch Dlo Kont Ensandi dwe a omwens katsan pye (400') de kote ki pi elwanye de bilding la, mezire pou aksè machin ak sou kote bilding nan. Distans maksimòm ant bouch dlo kont ensandi a pa dwe depase 500 pye.
-
- Lè li ekzije pa AHJ a, bouch dlo kont ensandi ki gen domaj swit a aksidan machin dwe pwoteje sof si li lokalize tou prè yon piblik.
-
- Lè rezèv dlo oswa bouch dlo kont ensandi yo pa fonksyone akòz de entretyen oswa reparasyon, yon endikatè ki vizib ki apwouve pa AHJ a dwe itilize pou endike ke bouch dlo a pa fonksyone.
-
- Yon minimòm 60 pous de espas vid dwe obsève nan alantou tout bouch dlo kont ensandi yo.

